

EC CONFORMITY DECLARATION

The Company SCHNEIDER ELECTRIC INDUSTRIES S A, 35 RUE JOSEPH MONIER
92500 RUEIL MALMAISON FRANCE

Declares that the product: Metal enclosures

NSYCRN (Spacial CRN), with or without suffix T
NSYCRNG (Spacial CRNG) with or without suffix T

NSYCRN22150, NSYCRN23150, NSYCRN252150, NSYCRN32510, NSYCRN325200, NSYCRN33150, NSYCRN33200, NSYCRN34200, NSYCRN345150, NSYCRN43150, NSYCRN43200, NSYCRN44200, NSYCRN46250, NSYCRN46300, NSYCRN54150, NSYCRN54200, NSYCRN54250, NSYCRN55250, NSYCRN64150, NSYCRN64200, NSYCRN64250, NSYCRN65150, NSYCRN65200, NSYCRN65250, NSYCRN66200, NSYCRN66250, NSYCRN66300, NSYCRN68300, NSYCRN75200, NSYCRN75250, NSYCRN86200, NSYCRN86250, NSYCRN86300, NSYCRN88200, NSYCRN88300, NSYCRN106250, NSYCRN106300, NSYCRN108250, NSYCRN108300

NSYCRNG86400, NSYCRNG810300D, NSYCRNG812300D, NSYCRNG106400, NSYCRNG108400, NSYCRNG1010300D, NSYCRNG1012300D, NSYCRNG1012400D, NSYCRNG126300, NSYCRNG126400, NSYCRNG128300, NSYCRNG128400, NSYCRNG1210300D, NSYCRNG1210400D, NSYCRNG1212300D, NSYCRNG1212400D, NSYCRNG1410300D

Provided that it is installed, maintained and used in the application for which it is made, with respect of the "professional practices", relevant installation and manufacturer's instructions.

Complies with the safety provisions for people and things required by the following Council Directives:

2006/95/CE *Low voltage*
89/106/CE - 93/68/CE *Construction*

Complies with the provisions of the following standards :

IEC 60529 : Degrees of protection provided by enclosures **IP-66**
Degrees of protection provided by enclosures **IP-55** (double door)
IEC 62262: Degrees of protection provided by enclosures against external mechanical impacts **IK-10**

Additional Information:

External Certification Bureau Veritas, Underwriters Laboratories, Germanisher LLoyds.

This product is intended to be installed, maintained and used by professional persons.

In the case of it is incorporated into an equipment submitted to the Directive 2006/42/CE and its modifications (Machinery Directive), this machinery must not be put into service until it has been declared to conform to the provisions of the Directive.

Year of affixing "CE" marking (old denomination CRN)	1996
Year of affixing "CE" marking (old denomination CRNG)	2007
Year of affixing "CE" marking (NSYCRN-NSYCRNG series, new denomination)	2010

11th May 2010



Stéphane DARIEL
Universal Enclosures Director
Schneider Electric Industries